



4 B Eves Drive, Suite 200
P.O. Box 961
Marlton, NJ 08053-3112

1 856.985.5600
1 856.810.9065

November 18, 2013

Mr. Edward McDonald, Board Chairman
Upper Captiva Island FD
P.O. Box 322
Pineland, FL 33945

RE: Upper Captiva Island FD, Lee County, FL
Public Protection Classification: 10
Prior Public Protection Classification: 7

Dear Chairman McDonald:

We wish to thank you, Chief Richard Pepper and others for your cooperation during our recent Public Protection Classification (PPC™) survey. Insurance Services Office (ISO®) has completed its analysis of the structural fire suppression delivery system provided in your community. The resulting classification is indicated above. This is a retrogression from the previous classification.

The primary reason for this retrogression is:

- 201.A.2. A Minimum of 4 firefighters responding on the initial alarm to all reported structure fires. The chief office may be 1 of the 4 responding firefighters.

We are not implementing the class change at this time. Before we make this change, we would like to know if you desire to develop a program to retain class 7. We request that you acknowledge this letter in writing within 30 days, and advise when this matter will be reviewed. If you choose to begin an improvement program, we would appreciate receiving a list of intended changes within 60 days. (The list of intended changes can be included in the 30 day letter if you wish.) In cases where improvements have not been completed within 12 months or by November 18, 2014 in this case, ISO will publish the retrogressed classification, but will continue to work with your community towards an improved future classification.

The PPC program is not intended to analyze all aspects of a comprehensive structural fire suppression delivery system program. It is not for purposes of determining compliance with any state or local law, nor is it for making loss prevention or life safety recommendations.



AIR WORLDWIDE

XACTWARE

If you have any questions about your classification, please let us know.

Sincerely,

Thomas Geibel

Thomas Geibel, CFPS

Email: tgeibel@verisk.com

Office: (312) 206-4186

Fax: (856) 985-2511

cc: Chief Richard Peppers, Fire Chief, Upper Captiva Island Fire Department
File